



TÜRKİYE DOPİNG KONTROL MERKEZİ
Hacettepe Üniversitesi, Eczacılık Fakültesi, 06100 Ankara, TÜRKİYE
Tel ve Fax : 90 (312) 310 67 76 Fax: 90 (312) 311 47 77

TURKISH DOPING CONTROL CENTER
Hacettepe University, Faculty of Pharmacy, 06100 Ankara, TURKEY
Tel and Fax : 90 (312) 310 67 76 Fax: 90 (312) 311 47 77

Sayı: B.30.2.HAC.0.AP.00.00/ 2004-363

07.09.2004

**“Sustop SS-10 Malzemesi”
Analiz Sonuçları**

ELEMENT	SİMGESİ	BİRİM	SINIR DEĞERİ	NUMUNE (Ortalama)	REAGENT BLANK
Alüminyum	Al	µg/L	15,0	<15,0	<15,0
Arsenik	As	µg/L	2,0	<2,0	<2,0
Kadmiyum	Cd	µg/L	0,5	<0,5	<0,5
Krom	Cr	µg/L	5,0	<5,0	<5,0
Demir	Fe	µg/L	20,0	<20,0	<20,0
Kurşun	Pb	µg/L	5,0	<5,0	<5,0
Nikel	Ni	µg/L	5,0	<5,0	<5,0
Selenyum	Se	µ/L	1,0	<1,0	<1,0
Mangan	Mn	µ/L	5,0	<5,0	<5,0

SONUÇ: “Sustop SS-10 Malzemesi’nin” BS 6920 standardına göre içme suyu ile teması uygundur.